

## may checklist 2021

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
DOMESTIC HOT WATER HEATER - ELECTRIC

SITE AND BLDG #: ny116-01    12685    water heater inventory  
 12686    10736    MECHANIC  
 10737    SIGNATURE: Ramon V  
 LOCATION/RM #:    WO# 12687    ASSET # 10738    START TIME:    FINISH TIME:  
 12688    10739

CHECK POINT	CHECKPOINT DESCRIPTION	10739	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
SPECIAL INSTRUCTIONS					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	check			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	check			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Attach drain hose. Drain several gallons from tank to remove sediment.	check			drain water heater
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	check			
3	Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters prior to checking connections.	check			
4	Check operation/ setting of aquastat. Check hot water temperature with dial thermometer, set aquastat at minimum value required for all uses.	check			
5	Check amperage draw of upper and lower elements and compare to name plate data.	check			
6	Clean element contacts, and check for proper closing under load.	check			
7	Clean pump, controls, switches, and starters. Check condition of pump seal or packing, and replace as required.	check			
8	If applicable, Remove and inspect Anode, replace if necessary	check			
9	Clean up work area and remove trash.	check			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: