

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

DOMESTIC HOT WATER HEATER - GAS

SITE AND BLDG #: VA012-01

MECHANIC
SIGNATURE: 

DATE: 6-FEB-2026

LOCATION/RM #:

WO# 21166

ASSET # 7073

START TIME: 1PM

FINISH TIME: 2PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●			
2	Use caution when working with natural gas fired equipment. Be aware of any smells (rotten egg) that could be a natural gas leak.	●			
3	Do not allow any open flames around equipment.	●			
TO BE PERFORMED AT EACH INSPECTION					
1	Attach drain hose. Drain several gallons from tank to remove sediment.	●			
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	●			
3	Check all connections - electric, gas and water. Tighten as necessary.	●			
4	Check operation and setting of aquastat. Check hot water temperature with dial thermometer, and set aquastat at minimum value required for all uses.	●			
5	Clean water heater exterior.	●			
6	Clean pump, controls, switches, and starters. Check operation of pump and condition of pump seal or packing, and replace as required.	●			
7	Soap test for gas leaks, if leaks are found notify facility manager and AFOS immediately.	●			
8	Clean up work area and remove trash.	●			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

State Ultraforce water heater checks out well with no issues.
-AS