

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DUCTLESS MINI SPLIT

SITE AND BLDG #: PA027

MECHANIC
SIGNATURE:*Pat Bernander*

DATE: 6/27/24


LOCATION/RM #:

WO# 15713

ASSET # See notes

START TIME: 8:00AM

FINISH TIME: 12:30PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	●		  
TO BE PERFORMED AT EACH INSP				
1	Check fan blades for dust buildup and clean if necessary.	●		
2	Check all electrical connections	●		
3	Check that the fan runs properly in all speeds as applicable.	●		
4	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary.	●		
5	Check filter door for proper gasketing and air leaks. Correct as needed.	●		
6	Change or Clean filter as needed. Filters get checked quarterly.	●		
7	Ensure condensate pump is working properly and that the drain lines are clear.	●		
8	Clean up work area.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and materials). If the repair cost exceeds \$250, the technician shall open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and description of the repair.

To be performed by: General Maintenance Worker

Additional Notes: Asset4661,4662,4664,4667,4668,4669,4670,4678,5120,5132,5133,