

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 Date of Visit: 3/16/22

Contractor Personnel on Site:

1. Patrick Brown 3. \_\_\_\_\_  
2. \_\_\_\_\_ 4. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. W0#'S , 16357-16359 , 16575 , 16590 , 16596 , 16426 ,
2. 16597
3. ASSET#'S , 9209-9211 , 9216 , 9265 , 190917- , 131 , 133 ,
4. 134 , 104-118 , 138-140
5. \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 3/16/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT SANCHEZ Date: 3/16/22

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DUCTLESS MINI SPLIT**

SITE AND BLDG #: **NY013 BLDG2**

LOCATION/RM #: **BLDG2** WO# **16597** ASSET # **190917-138-139**

MECHANIC  
SIGNATURE:DATE: **3/16/22**START TIME: **2:30pm**FINISH TIME: **3pm**


CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
<b>TO BE PERFORMED AT E/CH INSPECTION SERVICE</b>				
1	Check fan blades for dust buildup and clean if necessary.	✓		fan blades are clean
2	Check all electrical connections	✓		electrical connections are good
3	Check that the fan runs properly in all speeds as applicable.	✓		fan functions properly in all speeds
4	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary.	✓		all are clean
5	Check filter door for proper gasketing and air leaks. Correct as needed.	✓		No air leaks
6	Change or Clean filter as needed. Filters get checked quarterly.	✓		filters are good
7	Ensure condensate pump is working properly and that the drain lines are clear.	✓		drain lines are clear
8	Clean up work area.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**OUTDOOR CONDENSING UNIT**

SITE AND BLDG #: **NY013 BLDG2**LOCATION/RM #: **BLDG2 OUTSIDE** WO# **16597** ASSET # **190917-140**MECHANIC  
SIGNATURE: DATE: **3/16/22**START TIME: **1:30pm**FINISH TIME: **2pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Schedule outage of unit with personnel in area the unit serves.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Remove debris from air screen and clean underneath unit.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	screen and around unit are clean
2	Wash coil with coil cleaning solution - Rinse Thoroughly	<input checked="" type="checkbox"/>	<input type="checkbox"/>	coils are clean
3	Straighten fin tubes with fin comb, as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	fin tubes are straight
4	Check electrical connections for tightness.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	electrical connections are good
5	Check mounting base for tightness.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	mounting and base are good
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no excessive noise or vibration
7	Inspect all piping for leaks and tighten loose connections.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no leaks or loose connections
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	wires and insulation are good
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature and Humidity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Room temp <u>76</u> Room Humidity <u>48</u> %
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no replacement needed
11	Clean up work area.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: