

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DUCTLESS MINI SPLIT

SITE AND BLDG #: PA063

MECHANIC
SIGNATURE:

DATE: 12/17/2024



LOCATION/RM #:

WO# 17196

ASSET # See notes

START TIME: 11:00AM

FINISH TIME: 12:30PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	●	○	
TO BE PERFORMED AT EACH INSPECT				
1	Check fan blades for dust buildup and clean if necessary.	●	○	
2	Check all electrical connections	●	○	
3	Check that the fan runs properly in all speeds as applicable.	●	○	
4	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary.	●	○	
5	Check filter door for proper gasketing and air leaks. Correct as needed.	●	○	
6	Change or Clean filter as needed. Filters get checked quarterly.	●	○	
7	Ensure condensate pump is working properly and that the drain lines are clear.	●	○	
8	Clean up work area.	●	○	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per unit. Any repair cost exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the repair.

To be performed by: General Maintenance Worker

Additional Notes: Assets4644,4677,5130,513