

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DUCTLESS MINI SPLIT

MECHANIC
SIGNATURE: 

DATE: 9-SEP-2025

SITE AND BLDG #: VA033-02

LOCATION/RM #: WO# 20009 **ASSET #** 5249

START TIME: 1PM

FINISH TIME: 2PM


CHECK POINT	CHECKPOINT DESCRIPTION	TASK CO	SPECIAL INSTR	
			YES	NO
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	●		
TO BE PERFORMED AT EACH				
1	Check fan blades for dust buildup and clean if necessary.	●		
2	Check all electrical connections	●		
3	Check that the fan runs properly in all speeds as applicable.	●		
4	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary.	●		
5	Check filter door for proper gasketing and air leaks. Correct as needed.	●		
6	Change or Clean filter as needed. Filters get checked quarterly.	●		
7	Ensure condensate pump is working properly and that the drain lines are clear.	●		
8	Clean up work area.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PM complete on 6 piece Mitsubishi Mini Split. Filters cleaned on head units. Coils cleaned with no issues and outdoor unit is operating correctly with no issues.
 -AS



Page 1 of 1

