

## Tina Lee

---

**From:** Richard Hicks  
**Sent:** Monday, November 1, 2021 1:36 PM  
**To:** Grenier, Scott Anthony CIV USARMY 99 RD (USA); Williams-Taylor, Angela W CTR USARMY 99 RD (USA); Tina Lee  
**Cc:** Devlin, Thomas J CIV USARMY CENAP (US)  
**Subject:** Boiler Certification Update -VA050 CSS ticket needed

**Importance:** High

Hi Scott,

- VA701 boilers passed operational safety tests today
- VA050 Boilers passed operational safety test **EXCEPT** "Both boilers need the flue safety switch replaced .- The boilers are secured / OFF until flue safety switches are replaced – No heat in building .

- Please provide a CSS ticket to VA050-replace Flue safety switch on Boilers #1 & #2

Thanks,  
Rick

Rick Hicks  
Project Manager Region 5  
CMI Management Inc.  
5285 Shawnee Road Suite #510  
Alexandria,VA 22312  
703-738-5301  
Richard.Hicks@cmimgmt.com