

## Tina Lee

---

**From:** Richard Hicks  
**Sent:** Tuesday, May 10, 2022 3:00 PM  
**To:** Augustin, Kenneth P CIV USARMY 99 RD (USA); nathan.l.rigney.ctr@army.mil; Tina Lee  
**Cc:** Devlin, Thomas J CIV USARMY CENAP (US)  
**Subject:** MD021 WO 17237 Chiller Update CSS TICKET NEEDED

ken , Nathan,

The chiller at MD021 has been PM'd . Building Automation is not letting the chiller run due to satisfied building temps and Outside air temp is dropping .

We discovered a refrigerant oil leak on Circuit #1 by drier filter housing . Please provide a CSS ticket to repair the refrigerant leak .

Thanks,  
Rick

Rick Hicks  
PM / 99TH -Region 5  
5285 Shawnee Road  
Suite #510  
Alexandria , VA 22312  
703-738-5301  
Richard.Hicks@cmimgmt.com