

Tina Lee

From: Richard Hicks
Sent: Thursday, October 28, 2021 1:17 PM
To: Grenier, Scott Anthony CIV USARMY 99 RD (USA); Chipps, Christopher P CTR (USA); Tina Lee
Cc: Devlin, Thomas J CIV USARMY CENAP (USA)
Subject: VA002 Boiler Certification Update WO 15040 15041 15042 and >> CSS Ticket needed -October 28,2021
Attachments: Carbon Monoxide Sensors WO_13872.pdf
Importance: High
Follow Up Flag: Follow up
Flag Status: Completed

Scott, Team ,
VA002 boiler certifications are completed . All (3) Boilers passed Operational safety tests , But boiler #3 safety valve needs replaced -All boilers are online for heating season .

Note : We will not receive boiler certification due to Carbon Monoxide sensors not being installed . The 99th has been provided proposals and have been in discussions for direction to take. WO#13872 -See attached for your records.

Scott Please provide a CSS Ticket to replace the safety valve on boiler #3 at VA002

Thanks,
Rick

Rick Hicks
Project Manager Region 5
CMI Management Inc.
5285 Shawnee Road Suite #510
Alexandria,VA 22312
703-738-5301
Richard.Hicks@cmimgmt.com