

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 Date of Visit: 8/24/22

Contractor Personnel on Site:

1. Patrick Brown 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 18321 , 18322 , 18489-18492 , 18550 , 18558 ,
2. 18559 , 18573 , 18574 , 18582 , 18593 , 18603 , 18604 ,
3. 18644 , 18493 , 18494 , 18560 , 18495 , 18496 , 18646
4. ASSET#'S , 9932 , 9935 , 9898 , 9929 , 9933 , 9934 , 9930 ,
5. 9940 , 9941 , 9946 , 9947 , IL-31 , IL-33 , 190917-, 253 , 254 ,
269 , 250 , 251 , 263 , 268 , 243 , 244 , 271 , 273

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 8/24/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSGT MIKE SHIFFLETT Date: 8/24/22


Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY039 BLDG1**

LOCATION/RM #: **BLDG1** WO# **18491**, ASSET # **9933,**
18492, ASSET # **9934,**

MECHANIC
SIGNATURE: 

DATE: **8/24/22**

START TIME: **9am**

FINISH TIME: **9:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	190917-268	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Inspect for structural defects, note needed repairs	✓	/	/	
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	✓	/	/	
3	Clean exterior with dry cloth.	✓	/	/	
4	For Exit lights check for proper arrow direction.	✓	/	/	
5	Make and/or recommend any needed repairs.	✓	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: