

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 5/18/23

Contractor Personnel on Site:

1. Patrick Brown 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 21844 , 21845 , 21871 , 22062 , 22063 , 22064 ,
2. 22065 , 22077 , 22083 , 22094 , 22104 , 21872 , 22066 ,
3. 22067 , 21873 , 22068 , 22069 ,
4. ASSET#'S , 9932 , 9935 , 9898 , 9929 , 9933 , 9934 , 9890 ,
5. 9940 , 9941 , 9946 , 9947 , IL-31 , IL-32 , IL-33 , 190917- ,
5. 269,250,251,263,268,265,266

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 5/18/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mike SHIFFLETT Date: 5/18/23

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: NY039 BLDG1

22064, 9933,
 LOCATION/RM #: BLDG1 WO# 22065, ASSET # 9934,

MECHANIC
 SIGNATURE: 

DATE: 5/18/23

START TIME: 9:30am

FINISH TIME: 10am

CHECK POINT	CHECKPOINT DESCRIPTION	190917-268	TASK	COMPLETE	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Inspect for structural defects, note needed repairs		✓		
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket		✓		
3	Clean exterior with dry cloth.		✓		
4	For Exit lights check for proper arrow direction.		✓		
5	Make and/or recommend any needed repairs.		✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: