

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 BLDG1 Date of Visit: 2/8/22

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15904 , 15927 , 15931-15933 , 15960 , 15974 , 15987 , 15988 ,
2. 16009-16012 , 16183 , 16184 , 16241 , 16260 , 16271 , 16272 , 16185
3. ASSET#'S , 10043 , 10051-10054 , 10043 , 10066 , 10069 , 10044 ,
4. 10045 , 10067 , 10068 , 10063 , 10079 , 190917- , 279-284 , 288 , 294 ,
5. 299 , 295 , 296 , 279 , 286 , 301 ,

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/8/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOTT Date: 2/8/22

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EMERGENCY EXIT SIGNS AND WALL PACKS**

ACTIVITY AND BLDG #: **NY051 BLDG1 10067**

MECHANIC  
SIGNATURE:

DATE: **2/8/22**

LOCATION/RM #: **BLDG1 WO# 16011, ASSET # 10068**  
**16012, 190917-295,**

START TIME: **12pm**

FINISH TIME: **12:30pm**

CHECK POINT	CHECKPOINT IDENTIFICATION	296	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>					
1	Inspect for structural defects, note needed repairs	✓	/	/	no structural defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	✓	/	/	units function properly
3	Clean exterior with dry cloth.	✓	/	/	units have been wiped down
4	For Exit lights check for proper arrow direction.	✓	/	/	Arrow directions are proper
5	Make and/or recommend any needed repairs.	✓	/	/	no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**