

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 2/10/22

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15915 , 15941-15943 , 15981 , 15993 , 16075-16081 ,
2. 16197 , 16198 , 16242 , 16262 , 16275 , 16276 , 15944 , 15966 ,
3. 16082-16084 , 16236 , 16277 , 16085 , 16086
4. ASSET#'S , 10568 , 10564 , 10565 , 10569 , 10612 , 10559 , 10560 ,
5. 10566-10568 , 10613 , 10614 , 10608 , 10609 , 10628 , 10629 ,
10636-10638 , 10643 , 10644 , 190917- , 450 , 430-433 , 446 , 449 ,
434 , 447 , 452 , 455 , 458 , 459 ,-----

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/10/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: AMMIE MEARERO Date: 2/10/22

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY067 BLDG2**

LOCATION/RM #: **BLDG2** WO# **16083, 16084** ASSET # **10637 10638**

MECHANIC
SIGNATURE:

DATE: **2/10/22**

START TIME: **4:15pm**

FINISH TIME: **4:30pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	✓	/	no structural defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	✓	/	units function properly
3	Clean exterior with dry cloth.	✓	/	units have been wiped down
4	For Exit lights check for proper arrow direction.	✓	/	Arrow directions are proper
5	Make and/or recommend any needed repairs.	✓	/	no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: