

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
ENERGY RECOVERY VENTILATOR

SITE AND BLDG #: **NY127 BLDG2**

mechanical room

LOCATION/RM #: **WO# 23799, ASSET # 190917-,
24275 695,698,**MECHANIC
SIGNATURE: DATE: **9/6/23**START TIME: **12:30pm**FINISH TIME: **1pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check all moving components for proper lubrication. Apply lubrication where required.	✓		
2	Check dampers to ensure they open and close properly.	✓		
3	Check all fan belts for wear, tension, alignment, and dirt accumulation.	✓		
4	Check fan wheels and fasteners for oil and dust accumulation and clean as necessary.	✓	✓	
5	Check, clean, and/or replace both internal and external filters as necessary.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: