

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXHAUST FANS

SITE AND BLDG #: PA027

MECHANIC
SIGNATURE:

DATE: 12/4/2023

LOCATION/RM #: WO# 14472 ASSET # See notes

START TIME: 10:00AM

FINISH TIME: 11:30AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●	○	 
TO BE PERFORMED AT EACH INSPECTION				
1	Clean unit, especially fan blades.	●	○	 
2	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multiple belts should be replaced with matched sets.	●	○	
3	Perform required lubrication and remove old or excess lubricant.	●	○	
4	Clean motor with vacuum or low pressure dry air (less than 40 psig). Check for obstructions in motor cooling and air flow.	●	○	
5	Check structural members, vibration eliminators, and flexible connections. Check fan housing to ensure there is no damage and the housing is tight.	●	○	
6	Start unit and check for vibration and noise.	●	○	
7	Remove all trash and debris.	●	○	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). Any repair identified during PM exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: Asset#3683,3684,3685,3686,3687,3688,3689,3893