

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EXPANSION TANKS**

SITE AND BLDG #: PA062


MECHANIC  
SIGNATURE:*Pat Baum*

DATE: 6/24/24

LOCATION/RM #: WO# 15732 ASSET # 4861

START TIME: 12:00PM

FINISH TIME: 12:30PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		 
<b>TO BE PERFORMED AT EACH INSPECTION</b>				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	●		 
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	●		 
3	If applicable, check tank pressure via schrader valve. Correct as needed.	●		 

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). If repair cost exceeds \$250, open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and description of the repair.

To be performed by: General Maintenance Worker

Additional Notes: