

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: **NY070N01**
MECHANIC
SIGNATURE: **James R Groft Jr**
DATE: **03/11/2024****LOCATION/RM #:****WO# 15110****ASSET # 4837, 4862,
4863****START TIME:****FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	X		
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	X		
3	If applicable, check tank pressure via schrader valve. Correct as needed.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: