

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: **NY010 BLDG1**

mechanical room
LOCATION/RM #: WO# **14426** **ASSET #** **4987**

MECHANIC
SIGNATURE: DATE: **12/5/22**START TIME: **9am**FINISH TIME: **9:15am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETED YES	SPECIAL INSTRUCTIONS	
			TO BE PERFORMED AT EACH	
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓		
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	✓		
3	If applicable, check tank pressure via schrader valve. Correct as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor). For work exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, and description of work performed.

To be performed by: General Maintenance Worker

Additional Notes:

