

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 BLDG1 Date of Visit: 2/8/22

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15904 , 15927 , 15931-15933 , 15960 , 15974 , 15987 , 15988 ,
2. 16009-16012 , 16183 , 16184 , 16241 , 16260 , 16271 , 16272 , 16185
3. ASSET#'S , 10043 , 10051-10054 , 10043 , 10066 , 10069 , 10044 ,
4. 10045 , 10067 , 10068 , 10063 , 10079 , 190917- , 279-284 , 288 , 294 ,
5. 299 , 295 , 296 , 279 , 286 , 301 ,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/8/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOTT Date: 2/8/22

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: **NY051 BLDG1**

Mech room

LOCATION/RM #: **WO# 16260 ASSET # 190917-280,**MECHANIC
SIGNATURE: DATE: **2/8/22**START TIME: **12:30pm**FINISH TIME: **12:45pm**

CHECK POINT	CHECKPOINT DESCRIPTION	281	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.		✓	/	no sign of corrosion or leaks
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.		/	✓	no sight glass
3	If applicable, check tank pressure via schrader valve. Correct as needed.		✓	/	pressure is correct

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: