

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EXPANSION TANKS**

SITE AND BLDG #: **NY052 BLDG1**

103 mech room

LOCATION/RM #: **WO# 11450 ASSET # 5015**MECHANIC  
SIGNATURE:DATE: **12/7/22**START TIME: **10:30 am**FINISH TIME: **11am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SITE</b>				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓		
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	✓		
3	If applicable, check tank pressure via schrader valve. Correct as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). Any repair exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description.

To be performed by: General Maintenance Worker

**Additional Notes:**