

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 2/10/22

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

- | |
|--|
| 1. <u>WO#'S , 15915 , 15941-15943 , 15981 , 15993 , 16075-16081 ,</u> |
| 2. <u>16197 , 16198 , 16242 , 16262 , 16275 , 16276 , 15944 , 15966 ,</u> |
| 3. <u>16082-16084 , 16236 , 16277 , 16085 , 16086</u> |
| 4. <u>ASSET#'S , 10568 , 10564 , 10565 , 10569 , 10612 , 10559 , 10560 ,</u> |
| 5. <u>10566-10568 , 10613 , 10614 , 10608 , 10609 , 10628 , 10629 ,</u> |
| <u>10636-10638 , 10643 , 10644 , 190917-, 450 , 430-433 , 446 , 449 ,</u> |
| <u>434 , 447 , 452 , 455 , 458 , 459 ,-----</u> |

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/10/22

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: AMMIE MEARERO Date: 2/10/22

Signed: _____

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **EXPANSION TANKS**

SITE AND BLDG #: NY067 BLDG1

MECHANIC
SIGNATURE: 

DATE: 2/10/22

LOCATION/RM #: boiler room

WO# 16262

ASSET # 190917-432
190917-433

START TIME: 1:30pm

FINISH TIME: 1:45pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓		no sign of corrosion or leaks
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.		✓	no sight glass
3	If applicable, check tank pressure via schrader valve. Correct as needed.	✓		pressure is correct

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: