


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: NY070 BLDG2
LOCATION/RM #: mechanical room **WO#** 13758 **ASSET #** 4854

MECHANIC SIGNATURE:  **DATE:** 12/5/22
START TIME: 8am **FINISH TIME:** 8:15am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	
		YES	NO		
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			
TO BE PERFORMED AT EACH INSPECT					
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓			
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	✓			
3	If applicable, check tank pressure via schrader valve. Correct as needed.	✓			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). Any repair exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and description.

To be performed by: General Maintenance Worker

Additional Notes: