


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: NY070 BLDG1

mechanical room

LOCATION/RM #: WO# 14405 ASSET # 4837,4862,
4863MECHANIC
SIGNATURE: 

DATE: 12/5/22

START TIME: 9:45am

FINISH TIME: 10am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETED YES	SPECIAL INSTRUCTIONS	
			TO BE PERFORMED AT EACH	
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	✓		
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	✓		
3	If applicable, check tank pressure via schrader valve. Correct as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor). For work exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, and Task #.

To be performed by: General Maintenance Worker

Additional Notes:

