

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS**

MECHANIC
SIGNATURE:



DATE: 3/11/25

SITE AND BLDG #: VA039

LOCATION/RM #: WO# 18156 ASSET # 9080

START TIME: 10AM

FINISH TIME: 11AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.			
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.			
3	If applicable, check tank pressure via schrader valve. Correct as needed.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

ASSET 9080, expansion tank #1 is no longer used at VA039. Has been abandoned and replaced with ASSET 9081, expansion tank #2
-AS