

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

**MECHANIC
SIGNATURE:**

SITE AND BLDG #: VA039

DATE: 3/11/25

LOCATION/RM #: WO# 18156 **ASSET #** 9081

START TIME: 10AM

FINISH TIME: 11AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS		
		YES	NO			
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●				
TO BE PERFORMED AT EACH INSPECT						
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	●				
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.			N/A		
3	If applicable, check tank pressure via schrader valve. Correct as needed.	●				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Expansion Tanks checks out well with no issues.

-AS