

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EXPANSION TANKS**

SITE AND BLDG #: VA039-01

MECHANIC  
SIGNATURE: 

DATE: 9-JUN-2025

LOCATION/RM #: WO# 19068 ASSET # 9080

START TIME: 12PM

FINISH TIME: 1PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETED YES	SPECIAL INSTRUCTIONS
			TO BE PERFORMED AT EACH
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.		
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.		
3	If applicable, check tank pressure via schrader valve. Correct as needed.		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Expansion tank ASSET #9080 No longer in use. Has been abandoned  
 -AS