

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST EXPANSION TANKS

 MECHANIC
SIGNATURE:



DATE: 11-DEC-2025

SITE AND BLDG #: VA039-01

LOCATION/RM #: WO# 20690 ASSET # 9080

START TIME: 11AM

FINISH TIME: 12PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●			
TO BE PERFORMED AT EACH INSPECTION					
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	●			
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	●			
3	If applicable, check tank pressure via schrader valve. Correct as needed.	●			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Asset #9080 replaced by Asset #9081.
-AS

