

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: PA 053-01 Date of Visit: 2/12/19

Contractor Personnel on Site:

scott werry

1. scott werry
2. _____
3. _____
4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 7316
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: scott werry Date: 2/12/19
Signed: scott werry

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Al yochim Date: 2/12/19
Signed: Al yochim

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: Pp 053-01
LOCATION/RM #: MEP WO# 2316 ASSET # 7438

MECHANIC
SIGNATURE:

DATE:

START TIME: 8:30A.M

FINISH TIME: 8:45A.M

ITEMS NUMBER	DESCRIPTION	SPECIAL INSTRUCTIONS		NOTES
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
4	Open and tag switch.			
5	Inspect visual condition of wiring. Look for evidence of overheating.	✓		
6	Check for proper light operation.	✓		
7	Test operation of automatic switches/ time clock/ photocells if applicable.	✓		
8	Inspect light pole and mounting devices for deficiencies.	✓		
9	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		

Note: The technician shall perform