

ATTACHMENT J-0200000-05  
FORMS

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: P 087

Date of Visit: 2/8/19

Contractor Personnel on Site:

1. Tony Lazarus
2. Jim Geertgen
3. Scott Werry

- 4.
- 5.
- 6.

Work Performed:

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)


1. 7355
2. 7425
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgen

Date: 2-8-19


Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: C59 WOCEFF, JAMES T.

Date: 8 FEB 19

Signed: 

E-Mail: james.t.woeff.civ@mail.mil

**OTHER RECURRING SERVICES CERTIFICATION OF WORK**  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: P-082-01 Date of Visit: 2/8/19

Contractor Personnel on Site:

1. Tony Gravens
2. Jim Geertgens
3. Scott Werry
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Work Performed:

Other Recurring Services

1. 7317
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 2-8-19  
Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: \_\_\_\_\_

E-Mail: \_\_\_\_\_

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST  
LIGHTING, OUTSIDE

SITE AND BLDG #:

P 082 - 1

LOCATION/RM #:

MER WO# 7317

ASSET # 7439

MECHANIC  
SIGNATURE:

START TIME: 065~

DATE: 2/8/19

FINISH TIME: 07d ~

ITEM #	DESCRIPTION	SPECIAL INSTRUCTIONS	NOTES	
			PERFORMED	NOT PERFORMED
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Schedule and coordinate work with operating personnel.		✓	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
1	Open and tag switch.		✓	
2	Inspect visual condition of wiring. Look for evidence of overheating.		✓	
3	Check for proper light operation.		✓	
4	Test operation of automatic switches/time clock/photocells if applicable.		✓	
5	Inspect light pole and mounting devices for deficiencies.		✓	
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.		✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency to be performed by General Maintenance Worker.

Additional Notes:

2 pc