

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Pr 086 -01

Date of Visit: 2/14/19

Contractor Personnel on Site:

1. Tony Lozano
2. Jim Geertsema
3. Scott Welling

- 4.
- 5.
- 6.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)


1. 7380
- 2.
- 3.
- 4.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertsema

Date: 2-14-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mitchell Morrison SSC Date: 2-14-19

Signed: 

E-Mail: Mitchell.w.morrison.mil@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: *Pr 096-01*LOCATION/RM #: *mez 0*WO # *7320*ASSET # *7461*MECHANIC
SIGNATURE:

START TIME:

800

DATE:

*2/14/19*FINISH TIME: *815*

ITEM/PROCEDURE	DESCRIPTION	PERFORMED		NOTES/REMARKS
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
4	Open and tag switch.		✓	
5	Inspect visual condition of wiring. Look for evidence of overheating.	✓		
6	Check for proper light operation.	✓		
7	Test operation of automatic switches/ time clock/ photocells if applicable.	✓		
8	Inspect light pole and mounting devices for deficiencies.	✓		
9	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

*5 K Ruske**1 Set of Double Lights on Left Side out**1*

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #:

Pp 096-01

LOCATION/RM #:

WO# 7320

ASSET # 7443

MECHANIC
SIGNATURE

START TIME:

730

DATE: 2/14/19

FINISH TIME: 800

ITEM # (Q1830)	DESCRIPTION (Q1830) INSPECTION/REPAIR	SPECIAL INSTRUCTIONS	BASIC (Q1830) INSPECTION		NOTIFICATION
			MISS	INFO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			-	
2	Schedule and coordinate work with operating personnel.		-		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		-		
1	Open and tag switch.		-		
2	Inspect visual condition of wiring. Look for evidence of overheating.		-		
3	Check for proper light operation.		-		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		-		
5	Inspect light pole and mounting devices for deficiencies.		-		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.		-		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

2 R Single

1 Light on Romper car