



BACKFLOW PREVENTER
MOD. 110°F
9.0 PSI
N.D. 15
SER. 00300
CITY OF N.Y. MEA 141
SIZE 3
WATTS
ASSE
REGULATOR
GO
SVC
SP 084.4

[illegible]

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA166-01 Date of Visit: 2-26-19

Contractor Personnel on Site:

1. 2

Work Performed: Tested 3" water backflow on 1x provided

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WOM 7222 Asset # 7183

Service Calls - Service Call Number and Description

1. CSS#
2. CSS#
3. CSS#

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Matkovich Date: 2-26-19
Signed: Brian Matkovich

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Timothy S Peters Date: 26 Feb 19
Signed: [Signature]
E-Mail: _____

Asset # 7184-Backflow-

PA166-01

Asset # 7183-Backflow-

BACKFLOW PREVENTER TEST

WATTS

909

160754

3"

DATE	#1 CHECK	#2 CHECK	RELIEF PSI	PASSED
2/23/18	7.9	2.4	2.8	yes
2-26-19	8.2	2.6	3.2	yes