

BACKFLOW PREVENTER TEST

MAKE WATTS

MODEL 2000B

SERIAL # 15943

SIZE 3/4

DATE	#1 CHECK	#2 CHECK	RELIEF PSI	PASSED
2/23/18	#2 TEST COCK			
	LEAKS - FAIL			
2-26-18	Test Cocks	#2,3,4		
	Leaks - Failed			

SENTRY MECHANICAL, LLC.



BACKFLOW PREVENTER TEST

MAKE WATTS

MODEL 2000B

SERIAL # 15943

SIZE 3/4

DATE	#1 CHECK	#2 CHECK	RELIEF PSI	PASSED
2/23/18	#2 TEST COCK			
	LEAKS - FAIL			
2-26-18	Test Cocks	#2,3,4		
	Leaks - Failed			

SENTRY MECHANICAL, LLC.