

Date: 4/23/2025

Region: 4A
FAC ID: NY030

FEMS No.: 2992252
Maximo WO No.: 18014

Asset #: NA

Priority: Emergency



Original Work Request:

Facility temperature is 60 degrees. It doesn't appear the pumps are circulating hot water through the building. All the valves appear to be closed. Add: No remote emergency stop installed as required by ASME CSD-1 Part CE-110.

Description of Repairs Needed:

Tidewater Technicians reset boiler #1 and it is running at this time. Reached out to P&J to trouble shoot the controls. Labor and material to supply and install (2) E-switches for the boilers one at each door of the boiler room. (Each switch will be able to shut down all four boilers at once)

Labor:

	Labor Hrs	Labor Rate	Total
Technician (2 techs x 8 hours)	16	\$ 132.00	\$ 2,112.00
Truck Charge	2	\$ 50.00	\$ 100.00

Material List:

	Quantity	Cost	Total
Emergency shut down switches	2	\$ 213.50	\$ 427.00
		\$	-
		\$	-
		\$	-
		\$	-

Equipment List:

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-

PM WO History:

NA

Estimate Summary:

Labor	Material	Equipment
\$ 2,212.00	\$ 427.00	\$ 0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$2,639.00	\$316.68	\$158.34	\$3,114.02



April 15, 2025

Army Reserve Center
3126 Upper Lake Road
Horseheads, NY 14845

Attn: Julie Pape

Re: Install boiler emergency stop switches NY030 Horseheads, NY

Ms. Pape,

Postler & Jaeckle Service is pleased to provide a quote for labor and materials to install emergency shut down switches for the boilers at the doors of the boiler room as requested. Your cost for this service will be \$2112.00 for labor and \$427.00.00 materials, and \$100.00 truck charges for a total of \$2,639.00.00. Thank you for the opportunity to provide this quote for your facility. Please contact me with any questions or concerns.

Sincerely,

DAVE HENDEE
Field Sales Support
Postler & Jaeckle Corp.
2000 Lake Rd., Elmira, NY 14903
T 607-739-8303 | C 607-215-6523
E: dhendee@postler.com