

Date: 9/29/2025

Region: 4C

FEMS No.: 3220034

FAC ID: WV029

Maximo WO No.: 20089

Asset #: NA

Priority: Urgent



Original Work Request:

Repair constant leak in boiler line mech room in Motor Pool.

Description of Repairs Needed:

Labor and material to a.) troubleshooting found leaking drain valve. b.) valved off and drain one pump, c.) removed bad valve and replaced with new 1 1/4" ball valve, d.) filled up pipe and checked for leaks and bled air out.

Labor:

	Labor Hrs	Labor Rate	Total
Technicians	2.5	\$ 142.00	\$ 355.00
Trip Charge	30	\$ 1.75	\$ 52.50
	1	\$ (198.00)	\$ (198.00)

Material List:

	Quantity	Cost	Total
Ball valve	1	\$ 60.76	\$ 60.76
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-

Equipment List:

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-

PM WO History:

NA

Estimate Summary:

Labor	Material	Equipment
\$ 209.50	\$ 60.76	\$ 0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$270.26	\$32.43	\$16.22	\$318.91

Invoice - 296270**Date:** 09/26/2025**CTS Work Order:** 226418**Purchase Order #:** FEMS 3220034 WO 2008**Customer Contact:** Julie Pape**Casto Technical Services, Inc.**

PO Box 627

Charleston, WV 25322

(304) 346-0549 - (304) 346-8920 (fax)

Bill to: Tidewater, Inc
6625-A Selnick Drive
Suite A
Elkridge, MD 21075**Service at:** USARC - Morgantown WV029
228 Comfort Inn Drive
HQ 99th RSC
Morgantown, WV 26508**Terms:** Net 30 days - ELECTRONIC MAIL

All past due balances are subject to a monthly 1.5% finance charge.

For your convenience, we now accept Visa and Mastercard.

Description	Quantity	Amount
-------------	----------	--------

Investigate and provide customer with a quote for repair constant leak in boiler line mechanical room in the motor pool.

Labor Total:	\$355.00
Materials Total:	\$60.76
Trip Charge Total:	\$52.50

If you had a contract with us you would have saved: \$137.50

Subtotal:	\$468.26
Sales Tax:	\$0.00
Payments:	\$0.00
Total Due:	\$468.26