

Date: 3/24/2026



Region: 4A

FEMS No.: 3433241

FAC ID: NY030

Maximo WO No.: 20913

Asset #: NA

Priority: Urgent

Original Work Request:

Install lockable disconnect as required by ASME CSD-1 Part CE-11 O Para. (a). NBIC Part 2 Sect. 2.2.10.6 (b) Scanner blower motor switch not functioning properly. Switch protects the flame scanner from damage due to scanner blower motor failure. NOTE: Issues above are for boilers 1 – 4.

Description of Repairs Needed:

Labor and material to install lockable disconnects switches on 4 boilers.

Labor:	Labor Hrs	Labor Rate	Total
Technician	12	\$ 137.00	\$ 1,644.00
Truck Charge	2	\$ 75.00	\$ 150.00
			\$ -

Material List:	Quantity	Cost	Total
Lockable disconnect switches	4	\$ 43.75	\$ 175.00
			\$ -
			\$ -
			\$ -

Equipment List:	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

NA

Estimate Summary:

Labor	Material	Equipment
\$ 1,794.00	\$ 175.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$1,969.00	\$236.28	\$118.14	\$2,323.42



March 24, 2026

US Army Reserve
198 Cornwell St
Penn Yan, NY 14527

Attn: Julie Pape

Re: Install lockable disconnects

Ms. Demain,

Postler & Jaeckle Service is pleased to quote labor and material to install lockable disconnects switches on 4 boilers at NY030 Horseheads.

Your cost for this service will be 8 hours labor for \$1,096.00, \$175.00 for materials , and a \$75.00 truck charge for a total of \$1,346.00. This proposal is based on work being performed during normal working hours of 8:00am to 4:30pm Monday through Friday. Please contact me with any questions or concerns.

Sincerely,

Dave Hendee
Postler & Jaeckle Service
Cell: 607-215-6523

POSTLER & JAECKLE

PLUMBING · HEATING · AIR CONDITIONING
REFRIGERATION · SHEET METAL

24 HR EMERGENCY		1-800-724-4252
NEW YORK OFFICES		
ROCHESTER	MAIN	585-546-7450
	SERVICE	585-423-6214
ALBANY	SERVICE	518-459-0910
BINGHAMTON	SERVICE	607-757-0100
SOUTHERN TIER	SERVICE	607-739-8303
SYRACUSE	SERVICE	315-455-5587
NEW JERSEY & PENNSYLVANNIA	SERVICE	570-883-9563

Date 1/30/2026
Job No. 69446
Cost Code 000000308
Work Order No. 223911326
Ticket No. 20260114133930
Customer P.O. FEMS 3402427 WO 2007

Customer US ARMY CORPS OF ENGINEERS - HORSEHEADS (86823)
Address 3126 LAKE ROAD, HORSEHEADS NY 14845
Contact JOHN GRANATA/JODI (585-944-9099)
Description INSTALL LOCKABLE DISCONNECT AS REQUIRED BY ASME CSD-1 FEMS 3402427 WO 20759

EQUIPMENT

Manufacturer	Model	Serial No.	Location	No.	Desc.	Parts Spec.
Hydrotherm	Kn-6	KN-H-NET-MON-3781	Boiler room		Boiler #1	

WORK PERFORMED

Date	Description
1/27/2026	Got a request from Tidewater. They're looking to have lockable disconnects installed on all four boilers. I checked out what needs to be done to install switches with locks on them. Got a material quote from Southern tier electric supply. Worked with Rob on getting a quote put together.

MATERIAL

Category	PO No.	Description
----------	--------	-------------

LABOR

Date	Technician Name	Tech Id	ST	OT	DT	Shift	Remark
1/27/2026	Keith Debolt	91418	4.00				
Total			4.00				

TOOL RENTAL

Tool Description	Week Ending	M	T	W	T	F	S	S
------------------	-------------	---	---	---	---	---	---	---

SUBCONTRACTOR

RECOMMENDATION

Job Status	JOB STATUS COMPLETE	
Accepted By		
Tel		_____
Email	jodi.l.philipenko.civ@mail.mil	Signature
Comments		
Note: tools and materials may not reflect those listed on the final invoice.		_____
		Date