

Additional Funding Request

Site: WV046	WO# 5257	CSS # 14558	Asset# NA
Description of Repairs	Investment is labor and materials to repair a glycol leak on the hot water supply pipe for AHU-3 at USARC Parkersburg, WV046, CSS #14558.		
Diagnosis: Initial Work Order CSS# 14558	Glycol Leak AHU 3		
Explanation of Additional Costs for Repairs	Investment is labor and materials to repair a glycol leak on the hot water supply pipe for AHU-3 at USARC Parkersburg, WV046, CSS #14558.		
Additional Labor Cost to Perform Repairs	Mechanic- 8 x \$115= \$920.00 Apprentice- 8 x \$93= \$744.00		
Additional Material Cost to Perform Repairs	\$400.50		
Total Cost of Repair	\$2,064.50		

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046 Date of Visit: 8-10-18

Contractor Personnel on Site:

1. Rick Backer 2. James Fauley

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# 152467

Service Calls – Service Call Number and Description

1. CSS# 14558
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Rick Backer Date: 8-10-18
Signed: Rick Backer

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Mary Ann Patterson GS-07 Date: 10 Aug 2018
Signed: Mary Ann Patterson
E-Mail: mary.a.patterson1.mil@mail.mil

