



Asset# 4529. Unit heater is inoperable due to locked up fan motor. WO# 6721. Asset# 4274. Inop t-stat in OMS building. Request is for vendor to troubleshoot and repair issues.

### Proposal to provide & perform the following:

- Disassemble unit heater for asset 4274
- Troubleshoot unit for electric short
- Quote repair
- Start up
- Warranty

## CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: \_\_\_\_\_ Date of Visit: 2/20/19

Contractor Personnel on Site:

1. Seony Mahawuli \_\_\_\_\_

### Work Performed:

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# 71042 6684

### Service Calls – Service Call Number and Description

1. CSS# 17218
2. CSS# \_\_\_\_\_
3. CSS# \_\_\_\_\_

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Shane Davis Date: 2/20/19

Signed: Shane Davis

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: \_\_\_\_\_

E-Mail: \_\_\_\_\_

14<sup>th</sup> OM  
OFF I  
UNAU  
PER