




Asset# 4506- Overhead unit heater located in OMS building is inoperable and not producing heat. Request is for vendor to troubleshoot and repair.

Proposal to provide and perform the following:

- Provide and install Inducer Draft Assembly
- Start up
- Warranty



MAINTENANCE
RECORD

1000

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CRM)

Facility Building: PARC Date of Visit: 1-10-19

Contractor Personnel on Site:

1. Ken Koenig 2.

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WCO CASH PAY - WO 7144

Service Calls - Service Call Number and Description

1. CSC OMS PULLS Header Not operation

2. CSCN

3. CSCN

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Ken Koenig Date: 1-10-19

Signed: Ken Koenig

To be signed by Facility Manager:

I certify that the above named individual, representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed.

Print Name/Rank: Shaw, Fabian / MFG Date: 1-10-19

Signed: N. R.

Email: Shaw, F. Fabian.CHO@ncl.edu