



Routine- WO#6697-Asset# 4370- Gate valve on hot water unit heater is inoperable and needs to be repaired/replaced. Found by CMI during December PM.

Proposal to provide and perform the following:

- Remove old water heater
- Install new A. O. Smith Proline 20 Gallon energy saver electric water heater
- Install new expansion tank