


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: WV006MECHANIC
SIGNATURE:DATE: 12-4-2023LOCATION/RM #: WO# 14414 ASSET # 4865START TIME: 730 FINISH TIME: 330

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---|---|----------------------------------|-----------------------|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | <input checked="" type="radio"/> | <input type="radio"/> |  |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Check physical condition of feeder. Clean and/or repair as needed. | <input checked="" type="radio"/> | <input type="radio"/> | |
| 2 | Check valves for proper operation. Ensure no leaks are present and repair as needed. | <input checked="" type="radio"/> | <input type="radio"/> | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per occurrence. For any deficiencies exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: