

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT



SITE AND BLDG #: VA051-01

LOCATION/RM #: WO# 11462

MECHANIC SIGNATURE

DATE: 12/13/2022

START TIME: 11AM FINISH TIME: 12AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	<input checked="" type="checkbox"/>		
2	Initial and Date Filter (if disposable)	<input checked="" type="checkbox"/>		
3	Initial and Date Yellow Maintenance Tag (if applicable)	<input checked="" type="checkbox"/>		
ASSET #	SIZE	QTY	NOTES/ ACTIONS	
	Record Size :			
5219		10		
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	
			 	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: Filters have been cleaned and head units are in proper order.
-AS