

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 3/18/22

Contractor Personnel on Site:

- | | |
|-------------------------|------------|
| 1. <u>Patrick Brown</u> | 3. <u></u> |
| 2. <u></u> | 4. <u></u> |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 16323 , 16324 , 16391 , 16392 , 16442-16444 , 16578 ,
2. 16605 , 16325 , 16326 , 16413 , 16445 , 16446
3. ASSET#'S , 10035 , 10036 , 10066 , 10069 , 10046 , 10073 , 10077 ,
4. 10080 , 190917- , 294 , 299 , 278 ,
5.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 3/18/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ABBOTT Date: 3/18/22

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY051 BLDG1

LOCATION/RM #: mechanical room
mezzanine

WO# 16323,16324

MECHANIC
SIGNATURE: 

DATE: 3/18/22

START TIME: 7am

FINISH TIME: 7:30am

CHECKPOINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	☒	☒	
2	Initial and Date Filter (if disposable)	☒	☒	
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☒	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
10035	24x24x2	4		
	20x24x2	12		
10036	20x12x2	2		
	24x12x2	1		
	20x20x2	2		
	24x20x2	1		
	16x20x2	4		
	16x25x2	2		
NOTE : Any AHU with outside air -Filter gets replaced Quarterly				
All other filters get replaced annually But inspected Quarterly				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: