

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY051 BLDG1

LOCATION/RM #: mechanical room
mezzanine

WO# 21095,21096

MECHANIC
SIGNATURE: 

DATE: 3/8/23

START TIME: 7am

FINISH TIME: 8am

CHECKPOINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	☒	☒	
2	Initial and Date Filter (if disposable)	☒	☒	
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☒	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
10035	24x24x2	4		
	20x24x2	12		
10036	20x12x2	2		
	24x12x2	1		
	20x20x2	2		
	24x20x2	1		
	16x20x2	4		
	16x25x2	2		
NOTE : Any AHU with outside air -Filter gets replaced Quarterly				
All other filters get replaced annually But inspected Quarterly				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: