

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 9/30/22

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 18742 , 18981 , 19152 , 19164 , 19185 , 18743 ,
2. 18982 , 19153 , 19160 , 19165 , 19186,18983
3. ASSET'S , 190917-, 605-614 , 634 , 635 , 600 , 601 , 643 ,
4. 617 , 628 , 629 , 655 , 691 , 695 , 698 , 705 , 706 , 688 , 715 ,
5. 724 , 697 , 691-695 , 698 , IL-, 65,66,67

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 9/30/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LUFFMAN, LARS Date: 9/30/22

Signed: 

E-Mail: lars.luffman.civ@army.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY127 BLDG2

MECHANIC SIGNATURE:  **DATE:** 9/30/22

LOCATION/RM #: BLDG2 **WO#** 18743

START TIME: 12:30pm **FINISH TIME:** 1:30pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Initial and Date Filter (if disposable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Initial and Date Yellow Maintenance Tag (if applicable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
190917-691	16x24x2	1		
190917-695	15x11- 3/8 x3/8 box filter	4-2		15x11 are washable
190917-698	16x20x2 - 16x25x2 - 20x16x12	6-4-6		
190917-705	20x20x4	1		
190917-706	16x20x4	1		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: