

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: VA033-02

MECHANIC
SIGNATURE: 

DATE: 6-JUN-2025

LOCATION/RM #: WO# 19059

START TIME: 1PM

FINISH TIME: 2PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH				
1	Check, clean, and/or replace filters as required.	<input checked="" type="radio"/>	<input type="radio"/>	
2	Initial and Date Filter (if disposable)	<input checked="" type="radio"/>	<input type="radio"/>	
3	Initial and Date Yellow Maintenance Tag (if applicable)	<input checked="" type="radio"/>	<input type="radio"/>	
ASSET #	SIZE			
	Record Size :			
G043	N/A cleaned	X6		
				
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes:

6 piece mini Split operating flawlessly.
 Filters cleaned.
 -AS