

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**FIRE DETECTION AND ALARM SYSTEM (VISUAL INSPECTION ONLY)**

SITE AND BLDG #: NY126 BLDG2

**MECHANIC  
SIGNATURE:**

DATE: 7/31/23

LOCATION/RM #: BLDG2 WO# 13182, ASSET # G179,G180 ~~START TIME:~~ 11:15am FINISH TIME: 11:30am  
13183

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	FIRE ALARM CONTROL PANEL AND ANNUNCIATOR EQUIPMENT - Visually inspect pannel condition (connections, fuses, light-emitting diodes [LEDs]) Note any trouble signals and last annual certification date.	✓	/	
2	BATTERIES - Inspect for corrosion or leakage. Verify tightness of connections.	✓	/	
3	PULLS HANDLES - Verify all appear in working order without damage.	✓	/	
4	HEAT SENSORS - Verify all appear in working order without damage.	✓	/	
5	AUDIO VISUAL ALARMS - Verify all Alarms appear in working order without damage.	✓	/	
6	SMOKE DETECTORS - Verify all Smoke Detectors appear in working order without damage	✓	/	
7	MASS NOTIFICATION - Verify system is in good condition.	✓	/	
8	FIRE SPRINKLERS WET AND DRY TYPE - Verify system is in good condition. Inspect fire riser for leaks and/or damage.	✓	/	
9	FIRE HYDRANTS - Verify that fire hydrants are not leaking and have not been damaged.	✓	/	



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

### Additional Notes: