

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FIRE EXTINGUISHERS - MONTHLY INSPECTION

SITE AND BLDG #: NY010 BLDG2


**MECHANIC
SIGNATURE:** 

DATE: 4/3/23

LOCATION/RM #: BLDG2 **WO#** 12377 **ASSET #** G002

START TIME: 10:30am

FINISH TIME: 11am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Each extinguisher shall have an inspection tag securely attached that indicates the month and year the inspection was performed and the initials of the person performing the inspection shall be recorded.	✓			
TO BE PERFORMED AT EACH INSPECTION SET					
1	A visual inspection is a quick check to see that the fire extinguisher is in its proper location, that it is not blocked, is fully charged, and that it appears to be in good working order.	✓			
2	Check that extinguisher is in designated place	✓			
3	Check for no obstruction to access or visibility.	✓			
4	Check that pressure gauge reading or indicator is in the operable range or position.	✓			
5	Update tag indicating that inspection has been preformed. Include the date and your initials.	✓			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: