

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FIRE EXTINGUISHERS - MONTHLY INSPECTION

SITE AND BLDG #:


LOCATION/RM #: WO# 19269 ASSET # G037

MECHANIC
SIGNATURE: 

DATE: 1-JUL-2025

START TIME: 11AM

FINISH TIME: 12PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Each extinguisher shall have an inspection tag securely attached that indicates the month and year the inspection was performed and the initials of the person performing the inspection shall be recorded.	<input checked="" type="radio"/>	<input type="radio"/>	 
TO BE PERFORMED AT EACH INSPECTION				
1	A visual inspection is a quick check to see that the fire extinguisher is in its proper location, that it is not blocked, is fully charged, and that it appears to be in good working order.	<input checked="" type="radio"/>	<input type="radio"/>	
2	Check that extinguisher is in designated place	<input checked="" type="radio"/>	<input type="radio"/>	
3	Check for no obstruction to access or visibility.	<input checked="" type="radio"/>	<input type="radio"/>	
4	Check that pressure gauge reading or indicator is in the operable range or position.	<input checked="" type="radio"/>	<input type="radio"/>	
5	Update tag indicating that inspection has been performed. Include the date and your initials.	<input checked="" type="radio"/>	<input type="radio"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

All FE's at this location check out well with no issues.
-AS