

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GREASE TRAP**

SITE AND BLDG #: NY127 BLDG1MECHANIC  
SIGNATURE: DATE: 12/20/22LOCATION/RM #: outside WO# 20146 ASSET # 190917-643START TIME: 9amFINISH TIME: 9:30am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Insure proper grease disposal.-Tanks are pumped by local septic companies	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Remove lid. If the trap is equipped with removable baffles, remove them.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Make sure the flow restrictor on the inflow pipe is present.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Replace lid and baffles.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years. -In Maximo under WO#	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: