



**O.S. Electric ,Inc**  
**397 Cottonwood Dr**  
**Williamsville, NY 14221**

# Invoice

Date	Invoice #
1/31/2019	2952

Bill To
Tidewater Inc

Ship To

Description	Qty	Rate	Curr %	Amount
Work location at US Army Corps of Engineers 100 N Forest Rd Williamsville, NY 14221 Service Call CSS #17180 WO#7219 1/16/19 12:00- 2:45 Repair and replace switch in vault trouble shoot loss power in underground storage building Damaged wire can't restore power must dig underground for repair or replace. Estimate to repair underground faulty wire damage underground from building 1 to storage building, Option 1 if it is repairable \$6000.00 Option 2 Replace line underground with new conduit and wire \$11,000.00 this will include trenching.	2.45	85.00		208.25T
		0.00		0.00T

Thank you for your business.	<b>Subtotal</b>	\$208.25
	<b>Sales Tax (8.75%)</b>	\$18.22
	<b>Total</b>	\$226.47
	<b>Payments/Credits</b>	\$0.00
	<b>Balance Due</b>	\$226.47

Phone #	Fax #	E-mail	Web Site
716 689-7394	716 689-7394	louis@oselectric.com	www.oselectric.com